

Your Logo Here

Address 01234 567890 Town

CERTIFICATE NUMBER: ARC01

MINOR DOMESTIC ELECTRICAL INSTALLATION WORKS CERTIFICATE

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations

DRAFT

To be used only for minor electrical work which does not include the provision of a new circuit

PART 1: DETAILS OF THE MINOR WORKS

Client ARC CONSTRUCTION, Date minor works completed 18/08/2006, Contract reference, if any None, Description of the minor works DOUBLE SOCKET TO LOUNGE SPURED FROM KITCHEN SPUR BEHIND FRIDGE, Location/address of the minor works 33 New Road Shoreham West Sussex, Postcode BN11 5TQ

PART 2: DETAILS OF THE MODIFIED CIRCUIT

System type and earthing arrangements TN-C-S, Protective measures against electric shock ADS, Overcurrent protective device for the modified circuit BS(EN) BS 3871, Residual current device (if applicable) BS(EN) 61008 RCD, Details of wiring system used to modify the circuit Type PVC/PVC cables, Reference method 1, csa of live conductors 2.5 mm^2, csa of cpc 1.5 mm^2, Where the protective measure against electric shock is ADS, insert maximum disconnection time permitted by BS 7671 0.4 s, Maximum Zs permitted by BS 7671 1666 Ohm, Comments, if any, on existing installation NONE

PART 3: INSPECTION AND TESTING OF THE MODIFIED CIRCUIT AND RELATED PARTS Essential inspections and tests

Confirmation that necessary inspections have been undertaken, Confirmation of the adequacy of earthing, Confirmation of the adequacy of protective bonding, Confirmation of correct polarity, Maximum measured earth fault loop impedance, Zs 0.2 Ohm, RCD operating time at Idn (if RCD fitted) N/A ms, RCD operating time at 5 x Idn, if applicable N/A ms, Agreed limitations, if any, on the inspection and testing NONE

PART 4: DECLARATION

I/We CERTIFY that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS 7671: (IEE Wiring Regulations), amended to AMD Date and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection complied with BS 7671 except as detailed in Part 1. Name (CAPITALS) Inspector, Signature, Date 18/08/06, Name (CAPITALS) Reviewed By, Signature, Date 19/02/10, For and on behalf of (Trading Title of Domestic Installer) Your Company Name, Address Your Address Address 2 Town County Postcode POSTCODE, Registration Number 6 6 7 7 8 8 (The registration number is essential information)

DRAFT

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE GUIDANCE FOR RECIPIENTS

DRAFT

This certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with British Standard 7671 (the IEE Wiring Regulations).

You should have received an 'Original' Certificate and the contractor should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner. A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

This Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of British Standard 7671 at the time the Certificate was issued.

DRAFT